	Veneta Engineering s.r.l. 37135 VERONA Via Lovanio 8/10 Telefono 0458200948 telefax 0458201982 www.venetaengineering.it	Organismo notificato di certificazione europea n. 0505 Machine - Ascensori - Recipienti semplici a pressione - Rumore Organismo d'ispezione di tipo "A" Impianti elettrici	9101 VERIFICA ATTREZZATURE DA LAVORO
	Laboratorio di Prove		

Authorized by Ministero dello Sviluppo Economico on 15 Jan. 2008 pursuant to articles 10 & 11 part A of EEC Directive 89/686/EEC "PPE-Personal Protective Equipment" dated 01 Jan. 08 (G.U. no. 24 of 29 Jan. 08)

To:
HB SECURITY S.R.L.


39040 **VIA DELL ADIGE, 5**
CORTACCIA **BZ**

TEST REPORT No. Acceptance record no.	333/EN VA 80642	date: date:	20/12/2012 06/04/12	ORIGINAL
TESTS ON ANCHOR DEVICES - PROTECTION AGAINST FALL FROM A HEIGHT				EN 795 P9101

dates:	test start	18/12/2012	test end	18/12/2012	sample
samples delivered		SAME-AS PRODUCTS			

REF. (as declared by client)	MARKET NAME	PORTABLE POINT
	CHARACTERISTICS	MOBILE ANCHORING POINT FOR TWO USERS
	SAMPLING SITE	

GENERAL DATA	DECLARED CLASS (POINT 4.3)	B	PORTABLE TEMPORARY ANCHORING DEVICES
	FIXING BASE CONNECTED WITH 2 M8x25 BOLTS ON STEEL PIPE		
	MOBILE ANCHORING POINT		
	LOAD TO BE APPLIED TO FIXED HOOK		
	PROTOTYPE - standardized production not checked		




inspections, measures and tests carried out (*)


inspections	markings found on sample under inspection				
tests	STATIC test		point 5,2,3		TEST PASSED
	anchoring structure Steel pipe				
	applied force	kN	10	std value	10,0 OK
	(FORCE APPLIED IN THE DIRECTION IN WHICH SAID FORCE CAN BE APPLIED DURING OPERATION)				
	application time	min	3,1	minimum	3 OK
	THE DEVICE	HOLDS		THE LOAD	OK
	DYNAMIC test		point 5,3,2		TEST PASSED
	anchoring structure Steel pipe				
	falling mass	kg	100	std value	100,0 OK
	height of fall	mm	2510	min std value	2450,0 OK
				max std value	2550,0 OK
	(HORIZONTAL DISTANCE FROM THE ANCHORING POINT TO THE LOAD APPLICATION POINT MAX. 300 MM)				
THE DEVICE	HAS	REMAINED STABLE			
THE MASS	HAS	BEEN ARRESTED BY THE DEVICE			


ANALYSIS OUTCOMES STATIC LOAD TEST **PASSED** - DYNAMIC LOAD TEST **PASSED**

THE OVERALL OUTCOME OF THE TESTS CONFIRMS THE DECLARED CLASS

NOTES NV = not evaluated NC = not compliant

the experimenter
Muntean Mihai


the head of laboratory
dott.ing. Loris Turella




Veneta Engineering s.r.l.
 37135 VERONA Via Lovanio 8/10
 Telefono 0458200948 telefax 0458201982
 www.venetaengineering.it

Organismo notificato di certificazione europea n. 0505
 Macchine - Ascensori - Recipienti semplici a pressione - Rumore
 Organismo d'ispezione di tipo "A" Impianti elettrici
Laboratorio di Prove

9101
VERIFICA
ATTREZZATURE
DA LAVORO

Authorized by Ministero dello Sviluppo Economico on 15 Jan. 2008 pursuant to articles 10 & 11 part A of EEC Directive 89/686/EEC "PPE-Personal Protective Equipment" dated 01 Jan. 08 (G.U. no. 24 of 29 Jan. 08)

To:
HB SECURITY S.R.L.

VIA DELL ADIGE, 5
CORTACCIA

39040

BZ

TEST REPORT No.	333/EN VA	date:	20/12/2012	ORIGINAL
Acceptance record no.	80642	date:	06/04/12	
TESTS ON ANCHOR DEVICES - PROTECTION AGAINST FALL FROM A HEIGHT				EN 795 P9101

dates:	test start	18/12/2012	test end	18/12/2012	sample
samples delivered		SAME-AS PRODUCTS			

MARKET NAME	PORTABLE POINT
CHARACTERISTICS	MOBILE ANCHORING POINT FOR TWO USERS
REF. (as declared by client)	SAMPLING SITE

PRODUCT AND FIXING DIAGRAM

DEVICE DIAGRAM	
Picture	
ENGLISH	ITALIAN
Adjustable bracket	Staffa regolabile
Section	Sezione
Ladder	Scala
Through hole	Foro passante
For threaded insert	Per inserto filettato
Perimetral welding	Saldatura perimetrale
Complete penetration	Completa penetrazione
Coupling	Accoppiamento
Welded	Con saldatura
Fastening knob	Manopola a pomello per fissaggio
Bolt	Bullone
Cylinder-head bolt	Bullone testa cilindrica

the experimenter
 Muntean Mihai

the head of laboratory
 dott.ing. Loris Turella